

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0476:113

Page 1 of 1

CATEGORY: Boxes

LISTEE: Harrington Signal Inc., 2519 4th Ave, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Model HSPS-1P, HSPS-1T, HSPS-2T, HSPS-6T, with or without suffixes DAH, KL and WP non-coded manual pull stations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible control units. Models with suffix -WP are suitable for outdoor use.

XLF: 7150-1039:101

07-24-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager